



*Training & Inspections*

*Wayne Goodwin | Commissioner of Insurance*

*Tim Bradley | Assistant State Fire Marshal*

January 31, 2011

Mr. Eddie Weatherman  
Yadkin County Fire Marshal  
Post Office Box 1002  
Yadkinville, North Carolina 27055

Re: N Yadkin Fire District

Dear Mr. Weatherman:

We wish thank you, Chief Smith, and others for the cooperation given to our representative during our recent survey. We have completed our evaluation of the fire insurance classification for N Yadkin Fire District, and confirm that Class 5/9E continues to apply.

The purpose of our visit was to gather information needed to determine a fire insurance classification that may be used in the calculation of property insurance premiums. This survey was not conducted for property loss prevention or life safety purposes and no life safety or property loss prevention recommendations will be made.

Class 5 applies to all properties within five miles of fire insurance district with a fire flow of 3500 gpm or less and within a 1000' of a fire hydrant. The private and public protection at properties with larger needed fire flows are individually evaluated, and may vary from the 5/9E classification.

We are attaching a copy of the Grading Sheet and the results of the hydrant flow tests witnessed during our visit.

If you have any questions concerning our survey and grading, please let us know.

Sincerely,

Tim Bradley,  
Senior Deputy Commissioner

TB/sdl

cc: Mr. Danny Smith, Fire Chief  
Mr. Dean Norman, President of Board